



**ELECTRICAL KEY NOTES - PHASE 2**

- 1 ALL EXTERIOR FIXTURES SHALL BE CONTROLLED VIA PHOTOCELL. REFER TO PHASE 1 DRAWINGS FOR PHOTOCELL LOCATION.
- 2 CONTRACTOR SHALL PROVIDE DAYLIGHT HARVESTING CONTROLS PER ASHRAE CODE REQUIREMENTS IN SPECIFIED ROOMS.
- 3 COORDINATE FIXTURE MOUNTING LOCATION WITH MECHANICAL EQUIPMENT IN THIS ROOM.
- 4 CONTRACTOR SHALL SURFACE MOUNT FIXTURES TO THE BOTTOM OF EXPOSED TRUSSES IN THIS AREA.

**ELECTRICAL KEY NOTES - PHASE 1**

- 1 ALL EXTERIOR FIXTURES SHALL BE CONTROLLED VIA PHOTOCELL.
- 2 CONTRACTOR SHALL PROVIDE DAYLIGHT HARVESTING CONTROLS PER ASHRAE CODE REQUIREMENTS IN SPECIFIED ROOMS.
- 3 COORDINATE FIXTURE MOUNTING LOCATION WITH MECHANICAL EQUIPMENT IN THIS ROOM.
- 4 CONTRACTOR SHALL SURFACE MOUNT FIXTURES TO THE BOTTOM OF EXPOSED TRUSSES IN THIS AREA.
- 5 CONTRACTOR SHALL PROVIDE AND INSTALL ACUITY TOUCHSCREEN LIGHTING CONTROLLER n57IN-WH + PROGRAMMING OR APPROVED EQUAL TO CONTROL LIGHTING IN THE MAIN HALL.















