



REQUEST FOR INFORMATION

SUB/SUPPLIER: RLE Concrete

RFI NO. 001

BY: Ryan Weber

DATE: 7/16/26

PHONE: (616) 862-1226

BID CATEGORY NO. 2

BID CATEGORY NAME: Concrete

PROJECT: Montague Area Public Schools – Agricultural Classroom and Barn

PROJECT #: 22-136.03

SUBJECT: Exterior Concrete Portland Cement Color

REF. SPECIFICATION(S): 32 1313 – Concrete Paving – Part 2.1 / A / 1

REF. DRAWING(S): N/A

REF. DETAIL(S): N/A

TYPE OF QUESTION:

☒ Civil ☐ Structural ☐ Architectural ☐ Mechanical ☐ Electrical ☒ Other

Question:

- 1) Is grey cement acceptable in lieu of white cement for exterior concrete?
- 2) I do not see slab on grade on the bid schedule, will this go directly after UG Rough-Ins or after the building enclosure?


Subcontractor / Supplier Recommendation:

RESPONSE BY: ☒ WinBerg Construction, Inc. ☐ Architect / Engineer

Response:

- 1) Grey cement is acceptable and/or preferred for the exterior sidewalks and aprons.
- 2) Yes, slab on grade will be directly after UG Rough-Ins.

WinBerg Construction, Inc.

Signature: 

Date: 7/16/26

Architect / Engineer

Signature: 

Date: 7/22/26

Email all RFI's to WinBerg Construction, Inc. – Attn. Jared Mott at jared@winbergconstruction.com