



DEPARTMENT OF TECHNOLOGY, MANAGEMENT AND  
BUDGET  
State Facilities Administration  
Design & Construction Division

## CONSTRUCTION BID ADDENDUM NO. 2

This form identifies an Addendum to Bidding Documents, and incorporates interpretations or clarifications, modifications, acceptance of proposed "or equal" materials, and other information into the Bidding Documents. Addenda will be numbered by the Professional and distributed through [www.michigan.gov/SIGMAVSS](http://www.michigan.gov/SIGMAVSS) as an attachment.

TO: <b>ALL BIDDERS</b>		DATE ISSUED 6/5/2026
PROJECT NAME DNR- Hartwick Pines State Park- Visitor Center Exhibit Space Reno. Grayling, MI		FILE NUMBER 751/26054.HJD
PROFESSIONAL Anna Kindt, Integrated Architecture	PROJECT DIRECTOR Heather DeKorte	BID OPENING DATE: 6/10/2026
<ul style="list-style-type: none"> <li>- 1. Sheet AD0-1: Existing Conference Room double doors and frame to be salvaged to owner. Tagged note #2 will be revised to read "REMOVE EXISTING DOOR AND FRAME, SALVAGE TO OWNER.". Revised drawing will be issued at a later date.</li> <li>- 2. Bidder RFI Responses: <ul style="list-style-type: none"> <li>Q1. Is the GC required to include the Split Rock Studios proposal value in our bid, or will this scope be excluded from the GC bid and carried directly by the Owner? Please see the correspondence below from the Split Rock representative indicating he was directed by the client not to provide pricing to bidders. <ul style="list-style-type: none"> <li>A1. <b>Response:</b> <i>The GC is required to include Split Rock Studios exhibit fabrication and installation contract value in their bid. The Split Rock contract value is included in Section 00300-6.1 Base Bid Schedule as Base Bid Item No. 2. All GCs are to include the amount in their base bid and directly hold the contract with Split Rock as a required subconsultant.</i></li> <li>Q2. Could you please clarify the species of the existing wood base that we are to match for wall base types B-1a, B-1b, and B-1c? <ul style="list-style-type: none"> <li>A2. <b>Response:</b> <i>New wood wall base to match existing in grade, species, cut and finish. Samples to be reviewed and confirmed with awarded contractor. For bidding purposes, provide pricing based on Clear/Select, flat cut, white oak with finish per specs.</i></li> </ul> </li> </ul> </li> </ul> </li> </ul>		
<b>ACKNOWLEDGEMENT:</b> This Addendum must be acknowledged by the Bidder in the space provided in the Bid Summary and Bid Form. Failing to acknowledge Addenda may be cause for the Bid to be rejected. Addenda will become part of the Contract Documents.		
PROFESSIONAL: <i>A. Kindt</i>		DATE: 6/5/2026
APPROVED BY:		6/4/2026
PROJECT DIRECTOR: <i>Heather DeKorte</i>		DATE: Click to enter date